



**SOUTH VALLEY WATER RECLAMATION FACILITY
WEST JORDAN, UTAH**


PROJECT 5 LANDSCAPING

CLIENT PROJECT NO. 10548A10

**ADDENDUM NO. 1
TO THE
CONTRACT DOCUMENTS**

AUGUST 19, 2021

August 19, 2021



Bidders on the above-named project are hereby notified that the Bidding Documents are modified as indicated below. Bidders are required to acknowledge receipt of this Addendum in the space provided on the Document 00300 - Bid Form.

This Addendum shall become part of the Contract and provisions of the Contract apply.

SPECIFICATIONS

The following sections are modified as indicated below.

1. SECTION 00030 – NOTICE INVITING BIDS
 - a. Change the first paragraph starting with “Receipt of Bids.....” to read as follows:
 - 1) RECEIPT OF BIDS: Sealed Bids will be received at the office of the ENGINEER, Carollo Engineers Inc. located at 7090 South Union Park Avenue, Suite 600, Midvale, UT 84047 until 2:00 PM on September 3rd, 2021, for construction of the WORK at South Valley Water Reclamation Facility’s Project 5 Landscaping located at 7495 South 1300 West, West Jordan, Utah 84084. Any Bids received after the specified time and date, or not at the office of the ENGINEER will not be considered.
2. SECTION 02817 - IRRIGATION
 - a. Modify paragraph 2.07.A to read as follows:
 - 1) Control wire shall be #14, red insulation, stranded copper, direct burial wire. Type UF Bearing; UL approved for direct underground burial in National Electrical Code Class II, AWG sizes.

DRAWINGS

The following drawings are modified as indicated below.

1. DRAWING L-02 LANDSCAPE PLAN:
 - a. Add General Note 6 to read as follows:
 - 1) Sprinklers, Topsoil, and Sod area to be 2” sod, 2” topsoil, native backfill. Adjust native grade as needed for finished grade of sod to be at finished grade of top of concrete of mow curb or other sidewalk areas.
2. DRAWING L-03 LANDSCAPE DETAILS:
 - a. Detail D1 – 6” Concrete Curb, Mulch and Grade:
 - 1) Change 6” layer of topsoil..... to read 2” layer of topsoil
 - 2) Change the dimension of topsoil from 6” to 2”.